

Ref.No:11/DFO/Ballari/2025

Office of the District Fire Officer
Karnataka State Fire and Emergency Service
Ballari District, Ballari - 583 104.

Date 16/01/2025

ANNEXURE-I

Group B, Educational Buildings

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.

To,

The Secretary
Sri Navabharatha Vidya Vardhaka Sangha(R)
Vinayaka Nagara. 5th Cross, 6th Ward
Kampli. Kampli (Tq) Ballari(Dist)

Sub: Recommended to Issue of "Fire Safety Recommendation" to "Sri Vidyasagara Higher Primary School" Located at 21st Ward, Behind Kalika Temple, Kampli, Kampli Taluk, Ballari District.

Ref : Applicant Letter Dated on: 09-01-2025

With reference-01 to the subject above cited, the premises of "Sri Vidyasagara Higher Primary School" Located at 21st Ward, Behind Kalika Temple. Kampli, Kampli Taluk, Ballari District was inspected by Me Dated on 12-01-2025 with respect to fire prevention, fire fighting and evacuation measures to be complied premises and Submitted building details as under.

A. Details of the Building/Premises:-

01.	Name and Address of the applicant.	:	The Secretary Sri Navabharatha Vidya Vardhaka Sangha(R) Vinayaka Nagara. 5 th Cross, 6 th Ward Kampli. Kampli (Tq) Ballari(Dist)
02.	Name and Address of the premises.	:	"Sri Vidyasagara Higher Primary School " Kampli, Kampli Taluk, Ballari District 21 st Ward, Behind Kalika Temple. Kampli.Kampli (Tq) Ballari(Dist)
03.	Name and Address of the Building owner.	:	Sri P.Nageshwara Rao Sri T.Kotresh. Smt. P.Rohini. Sri Navabharatha Vidya Vardhaka Sangha(R) Vinayaka Nagara. 3 rd Cross, 6 th Ward Kampli. Kampli (Tq) Ballari (Dist)

04.	Number of Buildings	:	03 No's Building		
05.	Number of floors	:	Block-01: Ground + 1 Upper floor. Block-02: Ground Floor. Block-03: Ground + 1 Upper floor.		
06	Floor-wise details of occupancy :-				
		:	Block-01 Ground + 1 Upper floor.		
	Ground Floor	:	Class Room-10 No's Office Room-02 No's Toilet Room-02 No.		
	1st Floor	:	Staff Room- 01 No. Office Room- 01 No. Principal Room- 01 No. Cabin- 01 No. Hall- 01 No.		
		:	Block-02 Ground Floor		
	Ground Floor:	:	Lab Room- 03 No's Library- 01 No. Record Room- 01 No. Class Room- 05 No's Toilet Room- 02 No's		
		:	Block-03 Ground + 1 Upper floor.		
	Ground Floor:	:	Class Room-04 No's		
	1st Floor	:	Class Room-04 No's		
07	Height of the building	:	08.00 Mtrs	04.00 Mtrs.	08.20 Mtrs
08	Site area	:	8191.68 Sq.Mtr.		
09	Built-up area of each floor :-		Block-01	Block-02	Block-03
	Ground Floor	:	1179.27 Sq Mtrs	144.00 Sq Mtr	280.34 Sq Mtrs
	1 st Floor	:	1179.27 Sq Mtrs	--	280.34 Sq Mtrs
10	Total built-up area	:	2358.54 Sq Mtrs	144.00 Sq Mtrs.	560.68 Sq Mtrs
11	Surrounding properties:-				
	East	:	Open Land.		
	West	:	Open Land.		
	North	:	09 Mtr Wide Connecting Road.		
	South	:	Open Land.		
12.	Set back area available around the Building:-				
	East	:	10.00 Mtrs.	Recommended: To provide as per Local Zonal Regulations.	
	West	:	02.30 Mtrs.		
	North	:	04.50 Mtrs.		
	South	:	03.40 mtrs.		

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures are recommended & are considered absolutely essential from fire safety point of view:-

Sl. No. [01]	Details [02]	Existing [03]			Recommendations [04]		
01	Accessibility to Premises.	The premises is accessible from 09 Mtrs wide Annapurna Rice Mill Opposite Road at North Side.			-		
02	No of entrances.	01 No.			-		
03	Diesel generators.	Not Provided			Recommended to Provide 01 of Adequate Capacity of Diesel Generator & It should be connected to alternate power supply.		
04	No. of staircases available	No of staircase	:	Block-01 (02 No) (Each)	Block-02 (01 No)	Block-03 (01 No)	--
		Width of staircase	:	01.70 Mtr.	01.00 Mtr	00.90 Mtr	
		Width of treads	:	30 Cms.	30 Cms	28 Cms	
		Height of risers	:	15 Cms.	15 Cms	15 Cms	
		No of riser per flight	:	11 risers	15 risers	15 risers	
		Height of handrails	:	01.00 Mtrs.	01.00 Mtrs.	00.90 Mtrs	
05	Fire extinguisher	Provided 01 No ABC Fire Extinguisher each of 6 kg capacity Should be Located As Available Within 15 Mtrs Radius. in each floor & each Block.			01) 01 No of CO2 Fire Extinguisher of 4.5 kg capacity Should be Provided near each Electrical Panel Board And Electrical Room. Switch board. 02) 01 DCP Extinguishers of 4 kgs capacity Should be provided in the Kitchen if Provided for the purpose of mid day meal. 03) 06 No's of sand Bucket for		

			Electrical Switch board. 04) Two number of Hand gloves near the Electrical Switch board. [All the extinguishers suggested above should be with B.I.S. markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically].
06	Public address system	Provided Public address system with two way communication facility has to provide at each floor area near each staircase landing with its console at the control room located on the ground floor For Both Block-01 & 02 Block	Public address system with two way communication facility has to provide at each floor area near each staircase landing with its console at the control room located on the ground floor For Block-03 Separately.
07	First aid Hose reel hose System.	Provided Block-01. 01 No of Hose reel hose of 30 mtr length with drum and 02 no's delivery hose pipes minimum 2 ½ inch size of adequate length to reach the farthest point of each floor to be provided with a shut off branch having a nozzle of 2 mm size. The hose reel hose has been connected at each landing by means of an adaptor.	Recommended to Provided Block-03. 01 No of Hose reel hose of 30 mtr length with drum and 02 no's delivery hose pipes minimum 2 ½ inch size of adequate length to reach the farthest point of each floor has to be provide with a shut off branch having a nozzle of 2 mm size. The hose reel hose has been connected at each landing by means of an adaptor.
08	Terrace tank over respective tower terrace.	Provided Over Head Tank of 10,000 Ltrs for Fire Fighting purpose.	Adequate
09	At the terrace tank level with minimum pressure of 3.5 kg/cm ²	Provided 01 No. of 450 LPM Booster	Adequate
10	Escape routes	Provided Signage board is required with illuminated points for in which direction to	Adequate

		go outside from the building for staff & students and also separate light arrangement to the illumination board by doing from battery operated at Block-01, 02 & 03	
11	Fire order (Fire Safety Plans)	Not Displayed	The Notice board have been indicted the action should be taken by the employees in case of any emergency should be displayed with the telephone number of Kurugodu Fire Station i.e-08393-263301 & 112, and the telephone number of nearest Ambulance service and Police Station at Both Block-01 & 02
12	No Smoking Board	Displayed COTPA Sec-4 Direction No Smoking area Smoking hear is an offence Board is written in English & Kannada both language Shall be Prominently displayed at inside the Entry/Exit.	Adequate
13	Fire fighting training.	03 Persons got 02 days Basic fire fighting Training at Regional Fire office, Kalaburagi Fire Station as on Date: 21/11/2022 to 22/11/2022. 01) Sri.Narasappa 2022 12 3140 02) Sri. Veeresh 2022 12 3139 03) Sri. Doddabasappa 2022 12 3138	Adequate

14) Fire Precautionary Measures:

- 1) Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical cum panel premises.
- 2) Accumulation of combustible waste in and around the premises should be avoided.
- 3) The exit ways shall be always kept clear without any Obstruction.
- 4) Liquefied petroleum gas should not be stored in the building.
- 5) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- 6) During the class hours the class room doors shall not be locked from inside to outside.

- 7) As per Honorable supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on 14th of every year by conducting fire safety drills with co-ordinate with fire service department.


Hence this "Fire Safety recommendation" is issued to Low rise Educational Building "Sri Vidyasagara Higher Primary School" Located at 21st Ward, Behind Kalika Temple. Kampli, Kampli Taluk, Ballari District subject to strict adherence of the conditions as laid down in this Recommendations and to check the portable fire extinguisher & Hose reel hose, and to conduct drills periodically and the Management must not extend the height of the building beyond 15.0 meters. Subject to condition and compliance of the above recommendations in column-4 of serial-B within 3 months and compliance to undersigned.

The "Fire Safety recommendation" is valid for only one year from the date of issue.

Date- 16-01-2025

Place- Ballari.

Yours faithfully,



District Fire Officer

Karnataka State Fire and Emergency Service
Ballari District, Ballari.



PRINCIPAL

Sri Vidyasagara Higher Primary School
(Sri Navabharatha Vidyavardhaka Sangha(R))
21st Ward, Ballari Road,
KAMPLI-583132. Ballari (Dist)

Ref.No: 20/DFO/Ballari/CC/2025

Office of the District Fire Officer
Karnataka State Fire and Emergency Service
Ballari District, Ballari - 583 104.
Date 20/01/2025

To,

The Secretary
Sri Navabharatha Vidya Vardhaka Sangha(R)
Vinayaka Nagara. 5th Cross, 6th Ward
Kampli. Kampli (Tq) Ballari(Dist).

Sub: Issue of "Compliance certificate " to "Sri Vidyasagara Higher Primary School" Located at 21st Ward, Behind Kalika Temple, Kampli, Kampli Taluk, Ballari District.

Ref : 01) No:11/DFO/Ballari/2024 Date: 16-01-2025 "Fire Safety Recommendation" Issued by This Office.
02) Applicant Letter Dated : 18-01-2025
03) No:19/DFO/Ballari/2025 Date:20-01-2025 Inspection Report.

With reference to the subject cited above, As per reference (1) "Sri Vidyasagara Higher Primary School" Located at 21st Ward, Behind Kalika Temple. Kampli, Kampli Taluk, Ballari District was inspected by the District Officer Ballari District, Ballari had from the fire Prevention, fire fighting and evacuation point of view & Fire Safety Recommendation was issued to the above said institute for fire fighting system to be installed within 03 Months including training Part.

As per Reference (2) Applicant Requested to Issue the Compliance Certificate. As Per Applicant Request I Have inspected the Educational Building on Date: 20-01-2025 and Submitted their report as per Reference (3) that the applicant has Maintained all the recommendation made in the Recommendation and I checked and found the fire fighting systems are working in good condition during inspection & Recommended to issue the compliance certificate for the same.

Hence here with issuing The "Compliance Certificate" for your Above said School/College Building from fire prevention, fire fighting and evacuation point of view & recommended to maintain the same in good working condition at any time.

This Renewal Compliance certificate is valid for 14-01-2026 and it is renewable.


PRINCIPAL
Sri Vidyasagara Higher Primary School
(Sri Navabharatha Vidyavardhaka Sangha(R))
21st Ward, Ballari Road,
KAMPLI-583132. Ballari (Dist)

Your's Faithfully.

District Fire Officer
Karnataka State Fire and Emergency Service
Ballari District, Ballari.